

TECHNICAL NOTICE

FOR THE DOCUMENTS

ABM, KBM, TBM and TBV

Edition 2, 2021-11-01

The Swedish Nuclear Power Companies have jointly produced this document. Any revision of this document must be approved by mutual consultation between the companies.

Approved:

Anders Magnusson FKA, Erik Lindén OKG and Fredrik Olvmark RAB

Licensee administrators of the PAKT-documents

TABLE OF CONTENTS

1 INTRODUCTION..... 4

2 DECLARED CHANGES TO ABM EDITION 5..... 4

2.1 2.4.2 Analysis of deficiencies 4

2.2 2.4.5.1 Deficiencies in mechanical equipment which shall be reported to SSM..... 4

3 DECLARED CHANGES TO KBM EDITION 8..... 4

4 DECLARED CHANGES TO TBM EDITION 8..... 4

5 DECLARED CHANGES TO TBV EDITION 2..... 4

5.1 4.4.1 Designations for extent of inspection and supervision 4

LIST OF REVISIONS – TECHNICAL NOTICE

Edition	Reason for revision	Applicable pages	Date
1	New document	--	2018-01-23
2	Earlier changes to KBM and TBM are incorporated in respective document ed. 8. Additional changes to ABM.	Entire document See markings	2021-11-01

1 INTRODUCTION

This technical notice constitutes the official addendum to the power plant common application documents ABM, KBM, TBM and TBV prepared by the Swedish licensee.

The technical notice constitutes a clarification, correction or change in the wording of the ordinary PAKT-document. The formulations will be processed in each PAKT-document upon future updates.

2 DECLARED CHANGES TO ABM EDITION 5

2.1 2.4.2 Analysis of deficiencies

Analysis of deficiencies shall be reviewed by an accredited inspection body in quality class 4 inspection class C, which is now referred to as quality class 4 AFS class –.

2.2 2.4.5.1 Deficiencies in mechanical equipment which shall be reported to SSM

Quality class 4 inspection class A and B are now referred to as quality class 4 AFS class A and B.

3 DECLARED CHANGES TO KBM EDITION 8

No clarifications, corrections or changes exist.

4 DECLARED CHANGES TO TBM EDITION 8

No clarifications, corrections or changes exist.

5 DECLARED CHANGES TO TBV EDITION 2

5.1 4.4.1 Designations for extent of inspection and supervision

Section is changed as follows:

- E Inspection and/or testing¹ to be carried out and documented in-house (even by external) on their own responsibility.²
 - L Testing to be carried out and documented by Accredited Laboratory.
 - T Inspection and/or testing to be carried out and documented by the manufacturer/purchaser. Manufacturers or purchasers requirements.
 - B Activity to be supervised, verified, reviewed and/or approved by the licensee/purchaser.
 - Q Independent review and inspection to be carried out and/or approved by the inspection organisation of the licensee.
- 1) Testing carried out in conjunction with manufacturing of material and shapes may be carried out as in-house inspection provided that the manufacturer possess and adheres to a quality system certified by an Accredited Notified Body according to KBM 1.8.3.
 - 2) Personnel performing work must not inspect and approve their own work. Personnel performing in-house inspection must have the necessary expertise.